

Driller's Report

Well Location	QTR	SEC	TWP	RGE	E	<input checked="" type="checkbox"/> W	<input type="checkbox"/>	GPS Reading			
	R. Lot Parish							Lat. N49°7.6'8.60"			
	Remarks Libau, MB							Long. W97°1.1'4.66"			
Well Owner	Name John Kundert- Naturist Legacy Inc.							Location Sketch of Well			
	Address Box 1955, Stn Main				Phone						
	Winnipeg, MB R3C 3R2				Cell Phone						
Well Identification											
Well Use	Production	<input checked="" type="checkbox"/>	Test Well	<input type="checkbox"/>	Recharge	<input type="checkbox"/>	Observation	<input type="checkbox"/>			
Water Use	Domestic	<input checked="" type="checkbox"/>	Livestock	<input type="checkbox"/>	Industrial	<input type="checkbox"/>	Irrigation	<input type="checkbox"/>			
	Air-condition	<input type="checkbox"/>	Other	<input type="checkbox"/>	Specify						
Date well completed	May 12, 2011										
Depth Below Ground in Feet	DESCRIPTION WELL LOG							Water Record			
0	74	Sand									
74	88	Broken Limestone									
88	120	Limestone									
WELL CONSTRUCTION											
Depth Below Ground Level	Casing	Open Hole	Perforations	Gravel Pack	Casing Grout	Inside Diameter	Outside Diameter	Screen Slot size	TYPE	MATERIAL	MAKE
0	90	x				5 5/2			Insert Glued	PVC	
90	120		x			4 3/4					
70	40				x				Grout	Cement	
Top of Casing		2 Feet above				Below					
REMARKS:											
Well must be vented											
PUMPING TEST						CONTRACTOR					
Date of Test: May 12, 2011						License Number 592 11					
Pumping <input checked="" type="checkbox"/> Flowing <input type="checkbox"/> Rate 25 I.G.P.M.						Name Echo Drilling Ltd.					
Water level before pumping 8 Above <input type="checkbox"/> Below <input checked="" type="checkbox"/>						Address 307 PTH 12 N Steinbach, MB. R5G 1T8					
Pumping level at end of test 10 Above <input type="checkbox"/> Below <input checked="" type="checkbox"/>						Drill Operator Chris Loepky					
Duration of test 1 HRS Minutes											
Recommended pumping rate 15 I.G.P.M.											
With pump intake at 20 Feet below ground level											